

## *EU Declaration of Conformity*

---

<i>Product:</i>	<b>Global Moulded Case Circuit Breakers</b>	
-----------------	---	--

---

<i>Name and address of the manufacturer:</i>	<b>Rockwell Automation, Inc.</b> <b>1201 South 2<sup>nd</sup> Street</b> <b>Milwaukee, WI 53204</b> <b>USA</b>	<i>Name and address of the authorised representative:</i>	<b>Rockwell Automation B.V.</b> <b>Rivium Promenade 160</b> <b>2909 LM Capelle aan den IJssel</b> <b>The Netherlands</b>
--	---	---	---

---

*This declaration of conformity is issued under the sole responsibility of the manufacturer.*

---

<i>Object of the declaration:</i>	<b>Allen-Bradley 140G-J Series</b> (reference the attached list of catalogue numbers)		
-----------------------------------	--	--	--

---

*The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:*

2014/35/EU	Low Voltage Directive	(LVD)
2014/30/EU	EMC Directive	(EMC)
2011/65/EU	RoHS Directive	(RoHS)


---

*References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:*

EN 60947-2:2006 + A1:2009 + A2:2013	Low-voltage switchgear and controlgear – Part 2: Circuit-breakers
EN 50581:2012	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

---

*Signed for and on behalf of the above named manufacturer:*

<i>Place and date of issue:</i>	Milwaukee, WI USA	08-Sep-2017
<i>Name, function:</i>	Daniel L. Nachtigall – Technical Leader, Product Compliance Engineering	
<i>Signature:</i>		

---

<i>Catalogue number</i>	<i>Series <sup>1</sup></i>	<i>Description</i>
140G-JxXx		250 A circuit breaker frame per Nomenclature
140G-JTxx-x		250 A circuit breaker trip unit per Nomenclature
140G-Jxxx-x-x-x		250 A circuit breaker assembly per Nomenclature

1) If no series number is given, then all series are covered.

**NOMENCLATURE:**

**Circuit Breaker Frame:**

140G	-	J	6	X	3
I		II	III	IV	V

I	Product Type 140G – Global moulded case circuit breaker
II	Frame/Current Rating J – J frame/250 A JC – J frame/250 A – current limiting
III	Interrupting Rating/Breaking Capacity (Based on I <sub>c</sub> at 480V) 2 – 22 kA 3 – 35 kA 6 – 65 kA 0 – 100 kA
IV	Protection Type X – None, frame only
V	Number of Poles 3 – 3 poles 4 – 4 poles

**Circuit Breaker Trip Unit:**

140G	-	J	T	I	4	-	D12
I		II	III	IV	V		VI

I	Product Type 140G – Global moulded case circuit breaker
II	Frame/Current Rating J – J frame/250 A
III	Interrupting Rating/Breaking Capacity (Based on I <sub>c</sub> at 480V) T – None, trip unit only
IV	Protection Type C – Fixed thermal/fixed magnetic F – Adjustable thermal/adjustable magnetic H – Electronic LSI I – Electronic LSIG
V	Number of Poles 3 – 3 poles 4 – 4 poles
VI	Current Rating (* Denotes a two digit number) C* – Current ratings of 25...90 A D* – Current ratings of 100...250 A

NOMENCLATURE

Complete Circuit Breaker Assemblies:

140G	-	J	3	C	3	-	C60	-	SD	-	AA
I		II	III	IV	V		VI		VII		VIII

I	Product Type 140G – Global moulded case circuit breaker
II	Frame/Current Rating J – J frame/250 A JC – J frame/250A – current limiting
III	Interrupting Rating/Breaking Capacity (Based on I <sub>c</sub> at 480V) 2 – 22 kA 3 – 35 kA 6 – 65 kA 0 – 100 kA
IV	Protection Type C – Fixed thermal/fixed magnetic F – Adjustable thermal/adjustable magnetic H – Electronic LSI I – Electronic LSIG
V	Number of Poles 3 – 3 poles 4 – 4 poles
VI	Current Rating (* Denotes a two digit number) C* – Current ratings of 25...90 A D* – Current ratings of 100...250 A
VII	Factory-Installed Internal Options Blank – No installed option SJ – Shunt trip; 24...30V AC/DC SK – Shunt trip; 48...60V AC/DC SD – Shunt trip; 110...127V AC, 110...125V DC SA – Shunt trip; 220...240V AC, 220...250V DC SB – Shunt trip; 380...440V AC SC – Shunt trip; 480...525V AC UJ – Undervoltage release; 24...30V AC/DC UR – Undervoltage release; 48V AC/DC UD – Undervoltage release; 110...127V AC, 110...125V DC UA – Undervoltage release; 220...240V AC, 220...250V DC UB – Undervoltage release; 380...440V AC UC – Undervoltage release; 480...525V AC
VIII	Factory-Installed Internal Options Blank – No installed option KA – 1 auxiliary contact; 250V AA – 1 auxiliary contact; 1 alarm contact, 250V BA – 2 auxiliary contacts; 1 alarm contact, 250V DA – 1 trip unit alarm contact; 250V FB – 2 auxiliary contacts; 400V AB – 1 auxiliary contact, 1 alarm contact; 400V AJ – 1 auxiliary contact, 1 alarm contact; 24V DJ – 1 trip unit alarm contact; 24V KJ – 1 auxiliary contact, 24V