

EU Declaration of Conformity

Product: IEC Miniature Circuit Breakers

Name and address of the manufacturer: Name and address of the authorised representative:

Rockwell Automation Inc.

Rockwell Automation B.V.

Rivium Promenade 160

Milwaukee, WI 53204

Rockwell Automation B.V.

Rivium Promenade 160

2909 LM Capelle aan den Ijssel

VI CA The Notherlands

U.S.A. The Netherlands

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration: Allen-Bradley 1492-SPM Series
(reference the attached list of catalogue numbers)

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2014/35/EU Low Voltage Directive (LVD) 2011/65/EU RoHS Directive (RoHS)

References to the relevant harmonised standards used or references to the other technical specifications in relation to

which conformity is declared:

EN 60947-1:2007 + A1:2011+ Low-voltage switchgear and controlgear – Part 1: General rules

A2:2014

EN 60947-2:2006 + A1:2009 + Low-voltage switchgear and controlgear – Part 2: Circuit-breakers

A2:2013

EN 50581:2012 Technical documentation for the assessment of electrical and electronic

products with respect to the restriction of hazardous substances

Signed for and on behalf of the above named manufacturer:

Place and date of issue: Milwaukee, WI USA 27-June-2017

Name, function: Daniel L. Nachtigall, Technical Leader – Product Certification Engineering

Dain Ph. Nachtigall

Signature:



Catalogue number	Series 1	Description	
1492-SPMxxxxx		IEC miniature circuit breakers per Nomenclature	
189-AST1		Shunt trip, 1260 V AC/DC	
189-AST2		Shunt trip, 110415V AC, 110250V DC	

¹⁾ If no series number is given, then all series are covered

NOMENCLATURE

1492-SP	M	1	В	050	-	N
1	2	3	4	5		6

1	Designates Product	Line					
	1492-SP – IEC mini						
2	Designates Short Circuit Current Rating						
	M-15 kA						
3	Designates Number of Poles						
	1-1 pole						
	2-2 pole						
	3-3 pole						
4	Designates Trip Code						
	B – Trip Curve B						
	C – Trip Curve C						
	D – Trip Curve D						
5	Designates Current l	Rating	130 13 A 300 30 A				
	005 - 0.5 A	050 - 5 A	130 – 13 A	300 - 30 A			
	010 – 1 A	060 – 6 A	150 – 15 A	320 – 32 A			
	020 - 2 A	070 - 7 A	160 - 16 A	400 - 40 A			
	030 - 3 A	080 - 8 A	200 - 20 A	500 – 50 A			
	040 - 4 A	100 – 10 A	250 - 25 A	630 – 63 A			
6	Designates Neutral I	Pole					
	Blank – No neutral p						
	N – Neutral pole pro	vided					